


NOTE: 5'-0" MIN. COVER IN NYSOT ROW PAVEMENT
 3'-0" MIN. COVER IN NYSOT ROW OFF PAVEMENT
 3'-0" MIN. COVER IN ALL OTHER ROW

PRELIMINARY FOR INFORMATION ONLY

NOT FOR CONSTRUCTION



NO.	DATE	W.O.	DESCRIPTION	DESIGNED BY	CHECKED BY	DATE	APPROVED BY
0	7/18/17		ISSUED FOR BID/PERMIT	ES	PC/GS	PC/GS	APPD

PSEG-LI SOUTHOLD-SHELTER ISLAND SOUTHOLD, GREENPORT & SHELTER ISLAND, SUFFOLK COUNTY, NY	
INSTALLATION OF ELECTRIC CABLE	
PSEG-LI 117 Collins Park Riverhead, New York 11901	VENDOR DN-02
SCALE AS NOTED	DWG. NO. 31 OF 46
CAD/AN DWS FILE NO. DN16C603001.DWG	DWG. NO. 31 OF 46
SYSTEM GRID NUMBER	CORNET NO. FOLDER NO.