



**236 THIRD STREET
GREENPORT NY 11944**

**Tel: (631) 477-0248
Fax: (631) 477-1877**

MAYOR
GEORGE W. HUBBARD, JR.
Ext. 215

TRUSTEES
JACK MARTILOTTA
DEPUTY MAYOR
PETER CLARKE
MARY BESS PHILLIPS
JULIA ROBINS

VILLAGE ADMINISTRATOR
PAUL J. PALLAS, P.E.
Ext. 219

CLERK
SYLVIA PIRILLO, RMC
Ext. 206

TREASURER
ROBERT BRANDT
Ext. 217

Village of Greenport Road-End Water Quality Improvements for: Brown Street, Clark Street, and Fourth Street – 2019

Update September 10, 2019: Bid Related Q & A

1. Rip rap need stone size and detail as to dimensions of the install?

6-9" stone.

2. Sign bases need manufacturer if we have to supply?

Manufacturer must be Fossil Graphics Industries or equal. And Refer to the Green Innovation Grant Program (GIGP) Interpretative Sign Development Guidance Requirements for additional information.

3. Brown street curb needed at catch basin?

Yes.

4. Castings imported or American made? Big difference in price.

No Preference.

5. Binder how thick is the paving?

1.5" binder .5" top.

6. Does each area get fenced off with construction fence (plastic, or 6' chain link), or will barrels and cone do?

Barrels and cones are fine.

7. Fourth street 2 catch basins not noted as other streets?

Yes, supply and install. See detail #2.

8. Decommission sewer how?

Detach from existing manhole remove existing sewer pipe and tie in to new manhole.

9. Top pave NYSDOT type 6f?

As per Southold contract.

10. Mill street is there sufficient pavement to be able to mill 2"?

Mill existing asphalt as needed for installation of new asphalt.