



## Village of Greenport Road-End Water Quality Improvements for: Brown Street, Clark Street, and Fourth Street – 2019

### Update September 11, 2019: Bid Related Q & A

236 THIRD STREET  
GREENPORT NY 11944

Tel: (631) 477-0248  
Fax: (631) 477-1877

**MAYOR**

GEORGE W. HUBBARD, JR.  
Ext. 215

**TRUSTEES**

JACK MARTILOTTA  
DEPUTY MAYOR

PETER CLARKE

MARY BESS PHILLIPS

JULIA ROBINS

**VILLAGE ADMINISTRATOR**

PAUL J. PALLAS, P.E.  
Ext. 219

**CLERK**

SYLVIA PIRILLO, RMC  
Ext. 206

**TREASURER**

ROBERT BRANDT  
Ext. 217

1. 6" - 9" stone is good, how big is the swale 1' x 1, ' 5' x 2'? there is no detail

The cross section of the rip-rap should be 3' wide and 2' deep according to the DEC standard. To check the reference, follow this link.

[http://www.dec.ny.gov/docs/water\\_pdf/sec5bperm11.pdf](http://www.dec.ny.gov/docs/water_pdf/sec5bperm11.pdf)

2. Binder 1.1/2" top paving is 2" as per plan, or is the paving to be done by the Southold town bid, by others?

Refer to the Town of Southold code on asphalt installation.

3. If you call for 2" of top, you have to mill 2" to keep the grade, so again, is there more than 2 " to mill off and leave base to pave on?

Refer to the Town of Southold code on asphalt installation.